



中国国家强制性产品认证证书

证书编号: 2014010302736144

委托人名称、地址

上海涵嘉电气科技有限公司
浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

生产企业名称、地址

一二三电气有限公司
浙江省乐清市经济开发区经五路17弄9号

产品名称和系列、规格、型号

隔离器

HTG1-160; Ui: 750V; Ith: 160A; Ue: AC400V; Ie: 63A、80A、100A、125A、
160A; Icw: 10kA/1s; 使用类别: AC-20A; 极数: 3P, 4P

产品标准和技术要求

GB 14048.3-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2014年11月26日

有效期至: 2019年03月17日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1030126



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010302736144

NAME AND ADDRESS OF THE APPLICANT

Shanghai Hanjia Electrical Technology Co., Ltd.
No.1688, Xintanwa Road, Zhoupu Town, PudongNew District

NAME AND ADDRESS OF THE MANUFACTURER

One two three Electric Co. Ltd.
No.9,Lane 17 Jingwu Road, Economic Development Zone, Yueqing City,
Zhejiang Prov.

NAME AND ADDRESS OF THE FACTORY

One two three Electric Co. Ltd.
No.9, Lane 17 Jingwu Road, Economic Development Zone, Yueqing City,
Zhejiang Province, P.R.China

NAME, MODEL AND SPECIFICATION

Disconnecter

HTG1-160; Ui: 750V; Ith: 160A; Ue: AC400V; Ie: 63A, 80A, 100A, 125A,
160A; Icw: 10kA/1s; Utilization Category: AC-20A; Poles: 3P, 4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.3-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).


Date of issue: Nov.26, 2014 Date of expiry: Mar.17, 2019

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:


Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1030126



中国国家强制性产品认证证书

证书编号: 2014010305736147

委托人名称、地址

上海涵嘉电气科技有限公司
浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

生产企业名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

产品名称和系列、规格、型号

双电源自动转换开关

HTQ3-630; Ui: 500V; Ith: 630A; Ue: AC400V; Ie: 125A、160A、200A、250A、
315A、350A、400A、500A、630A; 使用类别: AC-33B; Icw: 12.6kA/60ms; Icm:
26kA; 电器级别: PC级; 转换方式: ATSE; 极数: 3P、4P

产品标准和技术要求

GB/T 14048.11-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2014年11月26日

有效期至: 2019年03月17日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1030127



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010305736147

NAME AND ADDRESS OF THE APPLICANT

Shanghai Hanjia Electrical Technology Co., Ltd.
No.1688, Xintanwa Road, Zhoupu Town, PudongNew District

NAME AND ADDRESS OF THE MANUFACTURER

One two three Electric Co. Ltd.
No.9,Lane 17 Jingwu Road, Economic Development Zone, Yueqing City,
Zhejiang Prov.

NAME AND ADDRESS OF THE FACTORY

One two three Electric Co. Ltd.
No.9,Lane 17 Jingwu Road, Economic Development Zone, Yueqing City,
Zhejiang Prov.

NAME, MODEL AND SPECIFICATION

Automatic Transformer Switching Equipment

HTQ3-630; Ui: 500V; Ith: 630A; Ue: AC400V; Ie: 125A, 160A, 200A, 250A,
315A, 350A, 400A, 500A, 630A; Utilization Category: AC-33B; Icw:
12.6kA/60ms; Icm: 26kA; ATSE Class: PC; Transfer Mode: ATSE; Poles: 3P, 4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.11-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Nov.26,2014 Date of expiry: Mar.17,2019

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1030127



中国国家强制性产品认证证书

证书编号: 2014010305736141

委托人名称、地址

上海涵嘉电气科技有限公司
浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

生产企业名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

产品名称和系列、规格、型号

双电源自动转换开关

HTQ3-100; Ui: 500V; Ith: 100A; Ue: AC400V; Ie: 16A、20A、25A、32A、40A、
50A、63A、80A、100A; 使用类别: AC-33B; Icw: 5kA/30ms; Icm: 8kA; 电器级别:
PC级; 转换方式: ATSE; 极数: 3P、4P

产品标准和技术要求

GB/T 14048.11-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2014年11月26日

有效期至: 2019年03月17日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1030128



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010305736141

NAME AND ADDRESS OF THE APPLICANT

Shanghai Hanjia Electrical Technology Co., Ltd.
No.1688, Xintanwa Road, Zhoupu Town, PudongNew District

NAME AND ADDRESS OF THE MANUFACTURER

One two three Electric Co. Ltd.
No.9,Lane 17 Jingwu Road, Economic Development Zone, Yueqing City,
Zhejiang Prov.

NAME AND ADDRESS OF THE FACTORY

One two three Electric Co. Ltd.
No.9,Lane 17 Jingwu Road, Economic Development Zone, Yueqing City,
Zhejiang Prov.

NAME, MODEL AND SPECIFICATION

Automatic Transformer Switching Equipment

HTQ3-100; Ui: 500V; Ith: 100A; Ue: AC400V; Ie: 16A, 20A, 25A, 32A, 40A,
50A, 63A, 80A, 100A; Utilization Category: AC-33B; Icw: 5kA/30ms; Icm:
8kA; ATSE Class: PC; Transfer Mode: ATSE; Poles: 3P, 4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.11-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Nov.26,2014 Date of expiry: Mar.17,2019

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1030128



中国国家强制性产品认证证书

证书编号: 2014010305736148

委托人名称、地址

上海涵嘉电气科技有限公司
浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

生产企业名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

产品名称和系列、规格、型号

双电源自动转换开关

HTQ2-125; Ui: 690V; Ith: 125A; Ue: AC400V; Ie: 20A、40A、63A、80A、100A、125A; 使用类别: AC-33iB; Icm: 17kA; Icw: 10kA/30ms; 电器级别: PC级; 转换方式: ATSE; 极数: 3P、4P

产品标准和技术要求

GB/T 14048.11-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2014年11月26日

有效期至: 2015年05月26日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1030129



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010305736148

NAME AND ADDRESS OF THE APPLICANT

Shanghai Hanjia Electrical Technology Co., Ltd.
No.1688, Xintanwa Road, Zhoupu Town, PudongNew District

NAME AND ADDRESS OF THE MANUFACTURER

One two three Electric Co. Ltd.
No.9,Lane 17 Jingwu Road, Economic Development Zone, Yueqing City,
Zhejiang Prov.

NAME AND ADDRESS OF THE FACTORY

One two three Electric Co. Ltd.
No.9,Lane 17 Jingwu Road, Economic Development Zone, Yueqing City,
Zhejiang Prov.

NAME, MODEL AND SPECIFICATION

ATSE

HTQ2-125; Ui: 690V; Ith: 125A; Ue: AC400V; Ie: 20A, 40A, 63A, 80A, 100A,
125A; Utilization Category: AC-33iB; Icm: 17kA; Icw: 10kA/30ms; ATSE
Class: PC; Transfer Mode: ATSE; Poles: 3P, 4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.11-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Nov.26,2014 Date of expiry: May.26,2015

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1030129



中国国家强制性产品认证证书

证书编号: 2014010305736136

委托人名称、地址

上海涵嘉电气科技有限公司
浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

生产企业名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

产品名称和系列、规格、型号

双电源自动切换开关

HTQ1-225/3P, HTQ1-225/4P; Ue: AC400V; Ui: 690V; 使用类别: AC-33iB; Ie:
63A、80A、100A、125A、140A、160A、200A、225A; Icm/Icn: 17kA /10kA; 电器级
别: CB级; 极数: 3P、4P, 转换方式: ATSE

产品标准和技术要求

GB/T 14048.11-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2014年11月26日

有效期至: 2019年03月17日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1030130



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010305736136

NAME AND ADDRESS OF THE APPLICANT

Shanghai Hanjia Electrical Technology Co., Ltd.
No.1688, Xintanwa Road, Zhoupu Town, PudongNew District

NAME AND ADDRESS OF THE MANUFACTURER

One two three Electric Co. Ltd.
No.9,Lane 17 Jingwu Road, Economic Development Zone, Yueqing City,
Zhejiang Prov.

NAME AND ADDRESS OF THE FACTORY

One two three Electric Co. Ltd.
No.9,Lane 17 Jingwu Road, Economic Development Zone, Yueqing City,
Zhejiang Prov.

NAME, MODEL AND SPECIFICATION

Automatic Transfer Switching Equipment

HTQ1-225/3P, HTQ1-225/4P; Ue: AC400V; Ui: 690V; Utilization Category: AC-
33iB; Ie: 63A, 80A, 100A, 125A, 140A, 160A, 200A, 225A; Icm/Icn:
17kA /10kA; ATSE Class: CB; Poles: 3P, 4P, Transfer Mode: ATSE

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.11-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Nov.26,2014 Date of expiry: Mar.17,2019

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1030130



中国国家强制性产品认证证书

证书编号: 2014010305736134

委托人名称、地址

上海涵嘉电气科技有限公司
浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

生产企业名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

产品名称和系列、规格、型号

双电源自动切换开关

HTQ1Y-100/3P, HTQ1Y-100/4P, HTQ1F-100/3P, HTQ1F-100/4P; Ue: AC400V; Ui: 690V; 使用类别: AC-33iB; Ie: 10A、16A、20A、25A、32A、40A、50A、63A、80A、100A; Icn: 5kA; Icm: 7.5kA; 电器级别: CB级; 转换方式: ATSE; 极数: 3P、4P

产品标准和技术要求

GB/T 14048.11-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2014年11月26日

有效期至: 2019年03月17日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1030131



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010305736134

NAME AND ADDRESS OF THE APPLICANT

Shanghai Hanjia Electrical Technology Co., Ltd.
No.1688, Xintanwa Road, Zhoupu Town, PudongNew District

NAME AND ADDRESS OF THE MANUFACTURER

One two three Electric Co. Ltd.
No.9,Lane 17 Jingwu Road, Economic Development Zone, Yueqing City,
Zhejiang Prov.

NAME AND ADDRESS OF THE FACTORY

One two three Electric Co. Ltd.
No.9,Lane 17 Jingwu Road, Economic Development Zone, Yueqing City,
Zhejiang Prov.

NAME, MODEL AND SPECIFICATION

Button of two power supply automation

HTQ1Y-100/3P, HTQ1Y-100/4P, HTQ1F-100/3P, HTQ1F-100/4P; Ue: AC400V; Ui:
690V; Utilization Category: AC-33iB; Ie: 10A, 16A, 20A, 25A, 32A, 40A,
50A, 63A, 80A, 100A; Icn: 5kA; Icm: 7.5kA; ATSE Class: CB; Transfer Mode:
ATSE; Poles: 3P, 4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.11-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Nov.26,2014 Date of expiry: Mar.17,2019

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1030131



中国国家强制性产品认证证书

证书编号: 2014010305736137

委托人名称、地址

上海涵嘉电气科技有限公司
浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

生产企业名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

产品名称和系列、规格、型号

双电源自动切换开关

HTQ1-63N/3P、HTQ1-63N/4P、HTQ1-63L/3P、HTQ1-63L/4P; U_i : 690V; U_e : AC400V;
 I_e : 6A、10A、16A、20A、25A、32A、40A、50A、63A; 使用类别: AC-33iB;
 I_{cm}/I_{cn} : 7.5kA /5kA; 电器级别: CB级; 转换方式: ATSE; 极数: 3P、4P

产品标准和技术要求

GB/T 14048.11-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2014年11月26日

有效期至: 2018年12月26日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1030132



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010305736137

NAME AND ADDRESS OF THE APPLICANT

Shanghai Hanjia Electrical Technology Co., Ltd.
No.1688, Xintanwa Road, Zhoupu Town, PudongNew District

NAME AND ADDRESS OF THE MANUFACTURER

One two three Electric Co. Ltd.
No.9,Lane 17 Jingwu Road, Economic Development Zone, Yueqing City,
Zhejiang Prov.

NAME AND ADDRESS OF THE FACTORY

One two three Electric Co. Ltd.
No.9,Lane 17 Jingwu Road, Economic Development Zone, Yueqing City,
Zhejiang Prov.

NAME, MODEL AND SPECIFICATION

Automatic Transfer Switching Equipment

HTQ1-63N/3P, HTQ1-63N/4P, HTQ1-63L/3P, HTQ1-63L/4P; Ui: 690V; Ue: AC400V;
Ie: 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A; Utilization Category: AC-
33iB; Icm/Icn: 7.5kA /5kA; ATSE Class: CB; Transfer Mode: ATSE; Poles:
3P, 4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.11-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Nov.26, 2014 Date of expiry: Dec.26, 2018

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1030132



中国国家强制性产品认证证书

证书编号: 2014010307736539

委托人名称、地址

上海涵嘉电气科技有限公司
浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

浙江索能电气有限公司
乐清市象阳工业区集艺路

生产企业名称、地址

浙江索能电气有限公司
乐清市象阳工业区集艺路

产品名称和系列、规格、型号

小型断路器

HTB1; Ue: AC230V(1P)、AC400V(2P、3P、4P); In: 6A、10A、16A、20A、25A、
32A、40A、50A、63A、80A、100A; C 型特性、D 型特性; Icn=Ics=6000A; 1P、2P、
3P、4P

产品标准和技术要求

GB 10963.1-2005

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2014年11月26日

有效期至: 2015年11月16日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1030133



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010307736539

NAME AND ADDRESS OF THE APPLICANT

Shanghai Hanjia Electrical Technology Co., Ltd.
No.1688, Xintanwa Road, Zhoupu Town, PudongNew District

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Suoneng Electrical Co.,Ltd.
Jiyi Road,Xiangyan Industrial Zone,Yueqing City

NAME AND ADDRESS OF THE FACTORY

Zhejiang Suoneng Electrical Co.,Ltd.
Jiyi Road,Xiangyan Industrial Zone,Yueqing City

NAME, MODEL AND SPECIFICATION

Miniature Circuit-breaker

HTB1; Ue: AC230V(1P)、AC400V(2P、3P、4P); In: 6A、10A、16A、20A、25A、
32A、40A、50A、63A、80A、100A; Type C、D; Icn=Ics=6000A; 1P、2P、3P、4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 10963.1-2005

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Nov.26, 2014

Date of expiry: Nov.16, 2015

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1030133



中国国家强制性产品认证证书

证书编号: 2014010302736542

委托人名称、地址

上海涵嘉电气科技有限公司
浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

浙江索能电气有限公司
乐清市象阳工业区集艺路

生产企业名称、地址

浙江索能电气有限公司
乐清市象阳工业区集艺路

产品名称和系列、规格、型号

隔离开关

HTB3; U_i : 400V; I_{th} : 125A; U_e : AC230V(1P)、AC400V(2P、3P、4P); I_e : 20A、25A、32A、40A、50A、63A、80A、100A、125A; I_{cm} : 2.1kA; I_{cw} : 1.5kA/1s; 使用类别: AC-22A; 极数: 1P、2P、3P、4P

产品标准和技术要求

GB 14048.3-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2014年11月26日

有效期至: 2016年09月26日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1030134



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010302736542

NAME AND ADDRESS OF THE APPLICANT

Shanghai Hanjia Electrical Technology Co., Ltd.
No.1688, Xintanwa Road, Zhoupu Town, PudongNew District

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Suoneng Electrical Co.,Ltd.
Jiyi Road,Xiangyan Industrial Zone,Yueqing City

NAME AND ADDRESS OF THE FACTORY

Zhejiang Suoneng Electrical Co.,Ltd.
Jiyi Road,Xiangyan Industrial Zone,Yueqing City

NAME, MODEL AND SPECIFICATION

Switch Disconnector

HTB3; Ui: 400V; Ith: 125A; Ue: AC230V(1P)、AC400V(2P、3P、4P); Ie: 20A、
25A、32A、40A、50A、63A、80A、100A、125A; Icm: 2.1kA; Icw: 1.5kA/1s;
Utilization Category: AC-22A; Poles: 1P、2P、3P、4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.3-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Nov.26,2014 Date of expiry: Sep.26,2016

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1030134



中国国家强制性产品认证证书

证书编号: 2014010302736139

委托人名称、地址

上海涵嘉电气科技有限公司
浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

生产企业名称、地址

一二三电气有限公司
浙江省乐清市经济开发区经五路17弄9号

产品名称和系列、规格、型号

隔离器

HTGI-630; Ui: 750V; Ue: AC400V; Ith: 630A; Ie: 315A、400A、500A、630A; 使用类别: AC-20A; Icw: 20kA/1s; 极数: 3P、4P

产品标准和技术要求

GB 14048.3-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2014年11月26日

有效期至: 2019年03月17日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1030135



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010302736139

NAME AND ADDRESS OF THE APPLICANT

Shanghai Hanjia Electrical Technology Co., Ltd.
No.1688, Xintanwa Road, Zhoupu Town, PudongNew District

NAME AND ADDRESS OF THE MANUFACTURER

One two three Electric Co. Ltd.
No.9, Lane 17 Jingwu Road, Economic Development Zone, Yueqing City,
Zhejiang Prov.

NAME AND ADDRESS OF THE FACTORY

One two three Electric Co. Ltd.
No.9, Lane 17 Jingwu Road, Economic Development Zone, Yueqing City,
Zhejiang Province, P.R.China

NAME, MODEL AND SPECIFICATION

Disconnecter

HTG1-630; Ui: 750V; Ue: AC400V; Ith: 630A; Ie: 315A, 400A, 500A, 630A;
Utilization Category:AC-20A; Icw: 20kA/1s; Poles: 3P, 4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.3-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Nov.26, 2014 Date of expiry: Mar.17, 2019

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1030135



中国国家强制性产品认证证书

证书编号: 2014010307738323

委托人名称、地址

上海涵嘉电气科技有限公司
上海市浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

生产企业名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

产品名称和系列、规格、型号

塑料外壳式断路器

HTM1-100/3300, HTM1-100/4300

Ui:690V;Ue:AC400V;In:16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A, 100A;过电流脱扣器类型:热磁式;Ics:22kA;Icu:35kA;使用类别:A类;3P, 4P

产品标准和技术要求

GB14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求,特发此证。

发证日期: 2014年12月02日

有效期至: 2019年03月17日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1041357



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010307738323

NAME AND ADDRESS OF THE APPLICANT

Shanghai Hanjia Electrical Technology Co., Ltd.
No. 1688 Xintanwa Road, Zhoupu Town, Pudong New District, Shanghai City

NAME AND ADDRESS OF THE MANUFACTURER

One two three Electric Co., Ltd.
No. 9, Lane 17, Jingwu Road, Economic Development Zone, Yueqing City

NAME AND ADDRESS OF THE FACTORY

One two three Electric Co., Ltd.
No. 9, Lane 17, Jingwu Road, Economic Development Zone, Yueqing City

NAME, MODEL AND SPECIFICATION

Moulded Case Circuit-breaker

HTM1-100/3300, HTM1-100/4300
Ui:690V;Ue:AC400V;In:16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A, 100A;Thermal Magnetic
Over-current Release;Ics:22kA;Icu:35kA;Utilization Category:A;3P, 4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB14048.2-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Dec. 02, 2014 Date of expiry: Mar. 17, 2019

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q 1041357



中国国家强制性产品认证证书

证书编号: 2014010307738325

委托人名称、地址

上海涵嘉电气科技有限公司
上海市浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

生产企业名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

产品名称和系列、规格、型号

塑料外壳式断路器

HTM1-225/3300, HTM1-225/4300
Ui: 690V; Ue: AC400V; In: 100A, 125A, 160A, 180A, 200A, 225A; 过电流脱扣器类型: 热磁
式; Ics: 22kA; Icu: 35kA; 使用类别: A类; 3P, 4P

产品标准和技术要求

GB14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2014年12月02日

有效期至: 2019年03月17日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1041358



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010307738325

NAME AND ADDRESS OF THE APPLICANT

Shanghai Hanjia Electrical Technology Co., Ltd.
No. 1688 Xintanwa Road, Zhoupu Town, Pudong New District, Shanghai City

NAME AND ADDRESS OF THE MANUFACTURER

One two three Electric Co., Ltd.
No. 9, Lane 17, Jingwu Road, Economic Development Zone, Yueqing City

NAME AND ADDRESS OF THE FACTORY

One two three Electric Co., Ltd.
No. 9, Lane 17, Jingwu Road, Economic Development Zone, Yueqing City

NAME, MODEL AND SPECIFICATION

Moulded Case Circuit-breaker

HTM1-225/3300, HTM1-225/4300
Ui:690V;Ue:AC400V;In:100A, 125A, 160A, 180A, 200A, 225A;Thermal Magnetic Over-
current Release;Ics:22kA;Icu:35kA;Utilization Category:A;3P, 4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB14048.2-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Dec.02, 2014

Date of expiry: Mar.17, 2019

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1041358



中国国家强制性产品认证证书

证书编号: 2014010309739879

委托人名称、地址

上海涵嘉电气科技有限公司
上海市浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

生产企业名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

产品名称和系列、规格、型号

控制与保护开关

HKBO-45 Ui:690V;Ue:AC400V;Ith:45A;Ie:1A, 3A, 6A, 10A, 16A, 20A, 32A, 45A;
Ics:15kA;AC-44;3P;1P20;配用的辅助触头:Ith:5A;AC-15 Ue/Ie:AC220V/2A

产品标准和技术要求

GB14048.9-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求,特发此证。

发证日期: 2014年12月05日

有效期至: 2017年07月09日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1047940



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010309739879

NAME AND ADDRESS OF THE APPLICANT

Shanghai Hanjia Electrical Technology Co., Ltd.
No.1688 Xintanwa Road, Zhoupu Town, Pudong New District, Shanghai City

NAME AND ADDRESS OF THE MANUFACTURER

One two three Electric Co., Ltd.
No.9, Lane 17, Jingwu Road, Economic Development Zone, Yueqing City

NAME AND ADDRESS OF THE FACTORY

One two three Electric Co., Ltd.
No.9, Lane 17, Jingwu Road, Economic Development Zone, Yueqing City

NAME, MODEL AND SPECIFICATION

Control and Protective Switching Device

HKBO-45 Ui:690V;Ue:AC400V;Ith:45A;Ie:1A, 3A, 6A, 10A, 16A, 20A, 32A, 45A;
Ics:15kA;AC-44;3P;IP20;Attached Auxiliary Contacts:Ith:5A;AC-15
Ue/Ie:AC220V/2A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB14048.9-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-02:2014).

Date of issue: Dec.05, 2014 Date of expiry: Jul.09, 2017

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1047940



中国国家强制性产品认证证书

证书编号: 2014010305740157

委托人名称、地址

上海涵嘉电气科技有限公司
浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

生产企业名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

产品名称和系列、规格、型号

双电源自动切换开关

HTQ2-3200; Ui: 690V; Ue: AC400V; Ie: 3200, 2500, 2000, 1250, 1000, 800, 630A; Ith: 3200, 2500, 2000, 1250, 1000, 800, 630A; Icw: 50kA/1s; 电器级别: PC级; 使用类别: AC-33iB; 极数: 3P、4P; 转换方式: ATSE

产品标准和技术要求

GB/T 14048.11-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2014年12月05日

有效期至: 2019年03月17日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1047936



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010305740157

NAME AND ADDRESS OF THE APPLICANT

Shanghai Hanjia Electrical Technology Co., Ltd.
No.1688, Xintanwa Road, Zhoupu Town, PudongNew District

NAME AND ADDRESS OF THE MANUFACTURER

One two three Electric Co. Ltd.
No.9,Lane 17 Jingwu Road, Economic Development Zone, Yueqing City,
Zhejiang Prov.

NAME AND ADDRESS OF THE FACTORY

One two three Electric Co. Ltd.
No.9,Lane 17 Jingwu Road, Economic Development Zone, Yueqing City,
Zhejiang Prov.

NAME, MODEL AND SPECIFICATION

Automatic Transfer Switching Equipment

HTQ2-3200; Ui: 690V; Ue: AC400V; Ie: 3200, 2500, 2000, 1250, 1000, 800,
630A; Ith: 3200, 2500, 2000, 1250, 1000, 800, 630A; Icw: 50kA/1s; ATSE
Class: PC; Utilization Category: AC-33iB; Poles: 3P, 4P; Transfer Mode:
ATSE

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.11-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Dec.05,2014 Date of expiry: Mar.17,2019

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1047936



中国国家强制性产品认证证书

证书编号: 2014010307738327

委托人名称、地址

上海涵嘉电气科技有限公司
上海市浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

生产企业名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

产品名称和系列、规格、型号

塑料外壳式断路器

HTM1-400/3300, HTM1-400/4300 Ui:690V; Ue:AC400V; In:200A, 250A, 315A, 350A, 400A;
过电流脱扣器类型:热磁式; Ics:35kA; Icu:50kA; 使用类别:A类; 3P, 4P

产品标准和技术要求

GB14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求, 特发此证。

发证日期: 2014年12月02日

有效期至: 2019年03月17日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1041364



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010307738327

NAME AND ADDRESS OF THE APPLICANT

Shanghai Hanjia Electrical Technology Co.,Ltd.
No.1688 Xintanwa Road, Zhoupu Town, Pudong New District, Shanghai City

NAME AND ADDRESS OF THE MANUFACTURER

One two three Electric Co.,Ltd.
No.9, Lane 17, Jingwu Road, Economic Development Zone, Yueqing City

NAME AND ADDRESS OF THE FACTORY

One two three Electric Co.,Ltd.
No.9, Lane 17, Jingwu Road, Economic Development Zone, Yueqing City

NAME, MODEL AND SPECIFICATION

Moulded Case Circuit-breaker

HTM1-400/3300, HTM1-400/4300
Ui:690V;Ue:AC400V;In:200A, 250A, 315A, 350A, 400A;Thermal Magnetic Over-current Release;Ics:35kA;Icu:50kA;Utilization Category:A;3P, 4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB14048.2-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-02:2014).

Date of issue: Dec.02,2014 Date of expiry: Mar.17,2019

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1041364



中国国家强制性产品认证证书

证书编号: 2014010307738333

委托人名称、地址

上海涵嘉电气科技有限公司
上海市浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

生产企业名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

产品名称和系列、规格、型号

万能式断路器

HTW1-2000/3P, HTW1-2000/4P

Ui:690V;Ue:AC400V;In:630A, 800A, 1000A, 1250A, 1600A, 2000A;过电流脱扣器类型:电子式;Ics:50kA;Icu:80kA;Icw:50kA/1s;使用类别:B类;3P, 4P

产品标准和技术要求

GB14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求,特发此证。

发证日期: 2014年12月02日

有效期至: 2018年12月05日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1041361



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010307738333

NAME AND ADDRESS OF THE APPLICANT

Shanghai Hanjia Electrical Technology Co.,Ltd.
No.1688 Xintanwa Road, Zhoupu Town, Pudong New District, Shanghai City

NAME AND ADDRESS OF THE MANUFACTURER

One two three Electric Co.,Ltd.
No.9, Lane 17, Jingwu Road, Economic Development Zone, Yueqing City

NAME AND ADDRESS OF THE FACTORY

One two three Electric Co.,Ltd.
No.9, Lane 17, Jingwu Road, Economic Development Zone, Yueqing City

NAME, MODEL AND SPECIFICATION

Conventional Circuit-breaker

HTW1-2000/3P, HTW1-2000/4P
Ui:690V;Ue:AC400V;In:630A, 800A, 1000A, 1250A, 1600A, 2000A;Electronic Over-current Release;Ics:50kA;Icu:80kA;Icw:50kA/1s;Utilization Category:B;3P, 4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB14048.2-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-02:2014).

Date of issue: Dec.02,2014 Date of expiry: Dec.05,2018

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1041361



中国国家强制性产品认证证书

证书编号: 2014010307738331

委托人名称、地址

上海涵嘉电气科技有限公司
上海市浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

生产企业名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

产品名称和系列、规格、型号

万能式断路器

HTW1-3200/3P, HTW1-3200/4P Ui:690V;Ue:AC400V;In:2000A, 2500A, 2900A, 3200A;过
电流脱扣器类型:电子式;Ics:65kA;Icu:85kA;Icw:65kA/1s;使用类别:B类;3P, 4P(三
个保护极, 第四极可开闭);配用的辅助触头:4NO4NC;Ith:5A;AC-15 Ue/Ie:AC220V/5A

产品标准和技术要求

GB14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求, 特发此证。

发证日期: 2014年12月02日

有效期至: 2018年10月25日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1041360



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010307738331

NAME AND ADDRESS OF THE APPLICANT

Shanghai Hanjia Electrical Technology Co., Ltd.
No. 1688 Xintanwa Road, Zhoupu Town, Pudong New District, Shanghai City

NAME AND ADDRESS OF THE MANUFACTURER

One two three Electric Co., Ltd.
No. 9, Lane 17, Jingwu Road, Economic Development Zone, Yueqing City

NAME AND ADDRESS OF THE FACTORY

One two three Electric Co., Ltd.
No. 9, Lane 17, Jingwu Road, Economic Development Zone, Yueqing City

NAME, MODEL AND SPECIFICATION

Conventional Circuit-breaker

HTW1-3200/3P, HTW1-3200/4P
Ui:690V;Ue:AC400V;In:2000A, 2500A, 2900A, 3200A;Electronic Over-current
Release;Ics:65kA;Icu:85kA;Icw:65kA/1s;Utilization Category:B;3P, 4P(With
three protective poles, Switched neutral pole);Attached Auxiliary
Contacts:4NO4NC;Ith:5A;AC-15 Ue/Ie:AC220V/5A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB14048.2-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).


Date of issue: Dec.02, 2014 Date of expiry: Oct. 25, 2018

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:


Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q 1041360



中国国家强制性产品认证证书

证书编号: 2014010307738328

委托人名称、地址

上海涵嘉电气科技有限公司
上海市浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

生产企业名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

产品名称和系列、规格、型号

塑料外壳式断路器

HTM1-630/3300, HTM1-630/4300 Ui:690V; Ue:AC400V; In:400A, 500A, 630A; 过电流脱扣器类型:热磁式; Ics:35kA; Icu:50kA; 使用类别:A类; 3P, 4P

产品标准和技术要求

GB14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求, 特发此证。

发证日期: 2014年12月02日

有效期至: 2019年03月17日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1041359



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010307738328

NAME AND ADDRESS OF THE APPLICANT

Shanghai Hanjia Electrical Technology Co., Ltd.
No. 1688 Xintanwa Road, Zhoupu Town, Pudong New District, Shanghai City

NAME AND ADDRESS OF THE MANUFACTURER

One two three Electric Co., Ltd.
No. 9, Lane 17, Jingwu Road, Economic Development Zone, Yueqing City

NAME AND ADDRESS OF THE FACTORY

One two three Electric Co., Ltd.
No. 9, Lane 17, Jingwu Road, Economic Development Zone, Yueqing City

NAME, MODEL AND SPECIFICATION

Moulded Case Circuit-breaker

HTM1-630/3300, HTM1-630/4300 Ui:690V;Ue:AC400V;In:400A, 500A, 630A; Thermal
Magnetic Over-current Release; Ics:35kA; Icu:50kA; Utilization
Category: A; 3P, 4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB14048.2-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification (REF
NO. CNCA-C03-02:2014).


Date of issue: Dec. 02, 2014 Date of expiry: Mar. 17, 2019

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:


Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q 1041359



中国国家强制性产品认证证书

证书编号: 2014010307736541

委托人名称、地址

上海涵嘉电气科技有限公司
浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

浙江索能电气有限公司
乐清市象阳工业区集艺路

生产企业名称、地址

浙江索能电气有限公司
乐清市象阳工业区集艺路

产品名称和系列、规格、型号

漏电断路器

HTB1L Ue: AC230V (1P+N, 2P), Ue: AC400V (3P, 3P+N, 4P); In: 6A、10A、
16A、20A、25A、32A、40A、50A、63A、80A、100A; Icn=Ics=6000A; I Δ n: 30mA/AC
型; C 型特性、D 型特性; I Δ m: 2000A; 1P+N、2P、3P、3P+N、4P; 电子式

产品标准和技术要求

GB 16917.1-2003, GB 16917.22-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2014年11月26日

有效期至: 2015年11月16日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1030123



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010307736541

NAME AND ADDRESS OF THE APPLICANT

Shanghai Hanjia Electrical Technology Co., Ltd.
No.1688, Xintanwa Road, Zhoupu Town, PudongNew District

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Suoneng Electrical Co.,Ltd.
Jiyi Road,Xiangyan Industrial Zone,Yueqing City

NAME AND ADDRESS OF THE FACTORY

Zhejiang Suoneng Electrical Co.,Ltd.
Jiyi Road,Xiangyan Industrial Zone,Yueqing City

NAME, MODEL AND SPECIFICATION

Residual Current Operated Circuit-breaker

HTB1L Ue: AC230V (1P+N, 2P) , Ue: AC400V (3P, 3P+N, 4P) ; In: 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A, 100A; Icn=Ics=6000A; I Δ n: 30mA/AC ; Type C, D; I Δ m: 2000A; 1P+N, 2P, 3P, 3P+N, 4P; ETU

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 16917.1-2003, GB 16917.22-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-02:2014).

Date of issue: Nov.26, 2014 Date of expiry: Nov.16, 2015

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1030123



中国国家强制性产品认证证书

证书编号: 2014010307736540

委托人名称、地址

上海涵嘉电气科技有限公司
浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

浙江索能电气有限公司
乐清市象阳工业区集艺路

生产企业名称、地址

浙江索能电气有限公司
乐清市象阳工业区集艺路

产品名称和系列、规格、型号

漏电断路器

HTB2L; Ue: AC230V; In: 6A、10A、16A、20A、25A、32A; C 型特性; $I\Delta n$: 30mA/AC 型/电子式; $I\Delta m$: 2000A; $I_{cn}=I_{cs}=3000A$; 2P (仅一个保护极)

产品标准和技术要求

GB 16917.1-2003, GB 16917.22-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2014年11月26日

有效期至: 2015年07月30日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1030124



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010307736540

NAME AND ADDRESS OF THE APPLICANT

Shanghai Hanjia Electrical Technology Co., Ltd.
No.1688, Xintanwa Road, Zhoupu Town, PudongNew District

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Suoneng Electrical Co.,Ltd.
Jiyi Road,Xiangyan Industrial Zone,Yueqing City

NAME AND ADDRESS OF THE FACTORY

Zhejiang Suoneng Electrical Co.,Ltd.
Jiyi Road,Xiangyan Industrial Zone,Yueqing City

NAME, MODEL AND SPECIFICATION

Residual Current Operated Circuit-breaker

HTB2L; Ue: AC230V; In: 6A、10A、16A、20A、25A、32A; Type C; I Δ n:
30mA/AC/ETU; I Δ m: 2000A; Icn=Ics=3000A; 2P (With 1 overcurrent
protective pole.)

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 16917.1-2003, GB 16917.22-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Nov.26,2014 Date of expiry: Jul.30,2015

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1030124



中国国家强制性产品认证证书

证书编号: 2014010302736146

委托人名称、地址

上海涵嘉电气科技有限公司
浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

一二三电气有限公司
乐清市经济开发区经五路17弄9号

生产企业名称、地址

一二三电气有限公司
浙江省乐清市经济开发区经五路17弄9号

产品名称和系列、规格、型号

隔离器

HTG1-250; Ui: 750V; Ith: 250A; Ue: AC400V; Ie: 180A、200A、225A、250A;
Icw: 10kA/1s; 使用类别: AC-20A; 极数: 3P、4P

产品标准和技术要求

GB 14048.3-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2014年11月26日

有效期至: 2019年03月17日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1030125



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010302736146

NAME AND ADDRESS OF THE APPLICANT

Shanghai Hanjia Electrical Technology Co., Ltd.
No.1688, Xintanwa Road, Zhoupu Town, PudongNew District

NAME AND ADDRESS OF THE MANUFACTURER

One two three Electric Co. Ltd.
No.9, Lane 17 Jingwu Road, Economic Development Zone, Yueqing City,
Zhejiang Prov.

NAME AND ADDRESS OF THE FACTORY

One two three Electric Co. Ltd.
No.9, Lane 17 Jingwu Road, Economic Development Zone, Yueqing City,
Zhejiang Province, P.R.China

NAME, MODEL AND SPECIFICATION

Disconnecter

HTG1-250; Ui: 750V; Ith: 250A; Ue: AC400V; Ie: 180A, 200A, 225A, 250A;
Icw: 10kA/1s; Utilization Category: AC-20A; Poles: 3P, 4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.3-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Nov.26, 2014 Date of expiry: Mar.17, 2019

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1030125



中国国家强制性产品认证证书


附录:

第 1 页 共 1 页

证书编号: 2015010307746917

纸号: 1062468

型号的解释:



注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2015010307746893

纸号: 1062467

型号的解释:



注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

证书编号: 2015010307746937

委托人名称、地址

上海涵嘉电气科技有限公司
上海市浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

浙江东安电器有限公司
浙江省乐清市北白象镇电器工业区

生产企业名称、地址

浙江东安电器有限公司
浙江省乐清市北白象镇电器工业区

产品名称和系列、规格、型号

塑料外壳式断路器

HTM3-100L/3300, HTM3-100L/3N300, HTM3-100L/4300, HTM3-100M/3300, HTM3-100M/3N300, HTM3-100M/4300
Ui:800V;Ue:AC400V;In:16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A, 100A;过电流脱扣器类型:热磁式;L型:Ics:35kA, Icu:50kA;M型:Ics:50kA, Icu:70kA;使用类别:A类;3P, 3P+N(三个保护极, N极常通), 4P(三个保护极, N极可开闭)

产品标准和技术要求

GB14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求, 特发此证。

发证日期: 2015年01月08日

有效期至: 2019年09月05日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1062005



中国国家强制性产品认证证书

证书编号: 2015010307746917

委托人名称、地址

上海涵嘉电气科技有限公司
上海市浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

浙江东安电器有限公司
浙江省乐清市北白象镇电器工业区

生产企业名称、地址

浙江东安电器有限公司
浙江省乐清市北白象镇电器工业区

产品名称和系列、规格、型号

塑料外壳式断路器

HTM3-250C, HTM3-250L, HTM3-250M

Ui:800V;Ue:AC400V;In:100A, 125A, 140A, 160A, 180A, 200A, 225A, 250A;过电流脱扣器
类型:热磁式;C型:Ics:25kA, Icu:35kA;L型:Ics:35kA, Icu:50kA;M
型:Ics:50kA, Icu:70kA;使用类别:A类;3P, 3P+N(三个保护极, N极常通), 4P(三个保护
极, N极可开闭);具体型号详见附录

产品标准和技术要求

GB14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求, 特发此证。

发证日期: 2015年01月08日

有效期至: 2019年09月05日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1062468



中国国家强制性产品认证证书

证书编号: 2015010307746893

委托人名称、地址

上海涵嘉电气科技有限公司
上海市浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

浙江东安电器有限公司
浙江省乐清市北白象镇电器工业区

生产企业名称、地址

浙江东安电器有限公司
浙江省乐清市北白象镇电器工业区

产品名称和系列、规格、型号

塑料外壳式断路器

HTM3-400C, HTM3-400L, HTM3-400M

Ui:800V;Ue:AC400V;In:225A, 250A, 315A, 350A, 400A;过电流脱扣器类型:热磁式;C型: Ics=Icu:35kA;L型: Ics=Icu:50kA;M型: Ics:50kA, Icu:70kA;使用类别:A类;3P, 3P+N(三个保护极, N极常通), 4P(三个保护极, N极可开闭);具体型号详见附录

产品标准和技术要求

GB14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2015年01月08日

有效期至: 2019年09月05日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1062467



中国国家强制性产品认证证书

证书编号: 2015010307746890

委托人名称、地址

上海涵嘉电气科技有限公司
上海市浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

浙江东安电器有限公司
浙江省乐清市北白象镇电器工业区

生产企业名称、地址

浙江东安电器有限公司
浙江省乐清市北白象镇电器工业区

产品名称和系列、规格、型号

漏电断路器

HTM3L-100/3300, HTM3L-100/3N300, HTM3L-100/4300
Ui:800V;Ue:AC400V;In:16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A, 100A;过电流脱扣器类型:热磁式;Ics:35kA;Icu:50kA;IΔn:100mA, 300mA, 500mA分级调节/AC型;剩余电流脱扣器类型:电子式;IΔm:12.5kA;使用类别:A类;3P, 3P+N(三个保护极, N极常通), 4P(三个保护极, N极可开闭)

产品标准和技术要求

GB14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求, 特发此证。

发证日期: 2015年01月08日

有效期至: 2019年08月28日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1062007



中国国家强制性产品认证证书

证书编号: 2015010307746895

委托人名称、地址

上海涵嘉电气科技有限公司
上海市浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

浙江东安电器有限公司
浙江省乐清市北白象镇电器工业区

生产企业名称、地址

浙江东安电器有限公司
浙江省乐清市北白象镇电器工业区

产品名称和系列、规格、型号

漏电断路器

HTM3L-225/3300, HTM3L-225/3N300, HTM3L-225/4300
Ui:800V; Ue:AC400V; In:100A, 125A, 140A, 160A, 180A, 200A, 225A, 250A; 过电流脱扣器
类型:热磁式; Ics:35kA; Icu:50kA; I Δ n:0.1A, 0.3A, 0.5A/AC型; 剩余电流脱扣器类型:
电子式; I Δ m:12.5kA; 使用类别:A类; 3P, 3P+N(三个保护极, N极常通), 4P(三个保护
极, N极可开闭)

产品标准和技术要求

GB14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求, 特发此证。

发证日期: 2015年01月08日

有效期至: 2019年09月05日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1062009



中国国家强制性产品认证证书

证书编号: 2015010307746891

委托人名称、地址

上海涵嘉电气科技有限公司
上海市浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

浙江东安电器有限公司
浙江省乐清市北白象镇电器工业区

生产企业名称、地址

浙江东安电器有限公司
浙江省乐清市北白象镇电器工业区

产品名称和系列、规格、型号

漏电断路器

HTM3L-400/3300, HTM3L-400/3N300, HTM3L-400/4300
Ui: 800V; Ue: AC400V; In: 225A, 250A, 315A, 350A, 400A; 过电流脱扣器类型: 热磁
式; Ics: 42kA; Icu: 65kA; I Δ n: 100mA, 300mA, 500mA (分级调整)/AC型; 剩余电流脱扣器
类型: 电子式; I Δ m: 16.5kA; 使用类别: A类; 3P, 3P+N (三个保护极, N极常通), 4P (三个保
护极, N极可开闭)

产品标准和技术要求

GB14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2015年01月08日

有效期至: 2019年08月28日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1062008



中国国家强制性产品认证证书

证书编号: 2015010307746892

委托人名称、地址

上海涵嘉电气科技有限公司
上海市浦东新区周浦镇新坦瓦公路1688号

生产者(制造商)名称、地址

浙江东安电器有限公司
浙江省乐清市北白象镇电器工业区

生产企业名称、地址

浙江东安电器有限公司
浙江省乐清市北白象镇电器工业区

产品名称和系列、规格、型号

漏电断路器

HTM3L-630/3300, HTM3L-630/3N300, HTM3L-630/4300
Ui:800V; Ue:AC400V; In:400A, 500A, 630A; 过电流脱扣器类型:热磁
式; Ics:42kA; Icu:65kA; I Δ n:300mA; 500mA; 1000mA分级调节/AC型; 剩余电流脱扣器类
型:电子式; I Δ m:16, 5kA; 使用类别:A类; 3P, 3P+N(三个保护极, N极常通), 4P(三个保护
极, N极可开闭)

产品标准和技术要求

GB14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求, 特发此证。

发证日期: 2015年01月08日

有效期至: 2019年08月28日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

